



JOHN ENGLER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF ENVIRONMENTAL QUALITY
CADILLAC DISTRICT OFFICE


FILE COPY



RUSSELL J. HARDING
DIRECTOR

August 6, 2002

Mr. Chris Hubbel
Williamsburg Receiving and Storage
10190 Munro Road
Williamsburg, Michigan 48690



Dear Mr. Hubbel:

Subject: Sampling Results of the Lagoon Water - Williamsburg Receiving and Storage,
Grand Traverse County.

A copy of the results of sampling the lagoon water on July 8, 2002, is enclosed. As you may recall, water was taken from the upper portion of the lagoon near the pump, and a second sample removed from the pump port, which would represent water from the lower level in the pond.

The results show that samples from the lower level in the pond were slightly higher in Biochemical Oxygen Demand, Sulfate, Total inorganic Nitrogen and Phosphorus. Chloride was slightly higher in the upper level sample. Both samples exceed groundwater permit discharge limits for land application.

If you have any questions regarding the results, feel free to give me a call.

Sincerely,

Janice Lee Heuer
Environmental Engineer
Waste Management Division
231-775-3960, Extension 6203

Enclosure